

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/08/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155448		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02, 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 07/06/2016	
NAME OF PROVIDER OR SUPPLIER LOWELL HEALTHCARE				STREET ADDRESS, CITY, STATE, ZIP CODE 710 MICHIGAN ST LOWELL, IN 46356			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 06/01/16 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 07/06/16</p> <p>Facility Number: 000361 Provider Number: 155448 AIM Number: 100266340</p> <p>At this PSR survey, Lowell Healthcare Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This facility was built as a two story building over a partial basement with a two story addition offset and connected to the original structure by a stairway prior to March 1, 2003. The facility refers to the levels as the first, second, third and fourth floors. The construction was determined to be of Type II (111) construction and was fully sprinklered. The facility has a fire alarm system with hard wired smoke detection in the corridors and common areas. Resident rooms are provided with battery powered smoke detector. The facility has the capacity for 86 and had a census of 76 at the time of this survey.</p> <p>All areas accessible to residents and all areas providing facility services are sprinklered.</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/08/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155448	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02, 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 07/06/2016
NAME OF PROVIDER OR SUPPLIER LOWELL HEALTHCARE			STREET ADDRESS, CITY, STATE, ZIP CODE 710 MICHIGAN ST LOWELL, IN 46356		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 1</p> <p>Quality Review completed on 07/07/16 - DA A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 06/01/16 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 07/06/16</p> <p>Facility Number: 000361 Provider Number: 155448 AIM Number: 100266340</p> <p>At this PSR survey, Lowell Healthcare Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This facility was built as a two story building over a partial basement with a two story addition offset and connected to the original structure by a stairway prior to March 1, 2003. The facility refers to the levels as the first, second, third and fourth floors. The construction was determined to be of Type II (111) construction and was fully sprinklered. The facility has a fire alarm system with hard wired smoke detection in the corridors and common areas. Resident rooms are provided with battery powered smoke detector. The facility has the capacity for 86 and had a census of 76 at the time of this survey.</p> <p>All areas accessible to residents and all areas providing facility services are sprinklered.</p>	{K 000}			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/08/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155448	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02, 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 07/06/2016
NAME OF PROVIDER OR SUPPLIER LOWELL HEALTHCARE			STREET ADDRESS, CITY, STATE, ZIP CODE 710 MICHIGAN ST LOWELL, IN 46356		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 2	{K 000}			
{K 000}	<p>Quality Review completed on 07/07/16 - DA INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 06/01/16 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 07/06/16</p> <p>Facility Number: 000361 Provider Number: 155448 AIM Number: 100266340</p> <p>At this PSR survey, Lowell Healthcare Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. The 2012 one story addition to the main dining room was surveyed with Chapter 18, New Health Care Facilities. 101, Life Safety Code (LSC), and 410 IAC 16.2. The 2005 addition of 14 rooms on E wing was surveyed with Chapter 18, New Health Care Facilities.</p> <p>This facility was built as a two story building over a partial basement with a two story addition offset and connected to the original structure by a stairway prior to March 1, 2003. The facility refers to the levels as the first, second, third and fourth floors. The construction was determined to be of Type II (111) construction and was fully sprinklered. The facility has a fire alarm system</p>	{K 000}			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/08/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155448	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01, 02, 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 07/06/2016
NAME OF PROVIDER OR SUPPLIER LOWELL HEALTHCARE			STREET ADDRESS, CITY, STATE, ZIP CODE 710 MICHIGAN ST LOWELL, IN 46356		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 3 with hard wired smoke detection in the corridors and common areas. Resident rooms are provided with battery powered smoke detector. The facility has the capacity for 86 and had a census of 76 at the time of this survey. All areas accessible to residents and all areas providing facility services are sprinklered. Quality Review completed on 07/07/16 - DA	{K 000}			